LISTING SERVICE

CATEGORY: Control Unit (High Rise)

LISTEE: Siemens Building Technologies Inc., Fire Safety Div., 8 Fernwood Rd, Florham Park NJ 07932
Contact: Peter Pawchak (973) 593-2662 FAX (973) 593-6652

DESIGN: Model "Firefinder" XLS fire alarm control unit. Local, auxiliary, remote station (protected premises), proprietary, central station (protected premises), waterflow and sprinkler supervisory service. Refer to listee's data sheet and control unit's installation instructions for additional detailed product description and operational considerations. System components:

PMI	Person Machine Interface
PSC-12	Power Supply
PTB	Power Termination Board
RPM	Remote Printer Interface
CRC-6	Relay Card
CC-2, -5	Card Cage
ZIC-4A	Zone Indicating Card
DLC	Device Loop Card
HTSW-1	Tamper Switch
NIC-C	Network Interface Card
5128, 5129	Silent Knight Dialer/DACT
LLM-1	Line Module
FCM-6	Fan Control Module
SCM-8	Switch Control Module
LCM-8	LED Control Module
CSB	CAN Sounder Board
PSX-12	Extender Power Supply
SIM-16	Supervised Input Module
OCM-16	Output Control Module
RNI	Remote Network Interface
HTRI-M, -S, -D, -R	Addressable Monitor Module
CAB2-BB, CAB3-BB	Enclosure
CAB-MP	Mounting Plate
CAB2-BD, -RD, -XBD	Enclosure Door
CAB3-BD, -RD, -XBD	Enclosure Door
CAB1-TK, CAB1R-TK, CAB2-TK,	Enclosure Trim Kit
CAB2R-TK, CAB3-TK, CAB3R-TK	Enclosure Trim Kit
CAB-BATT	Battery Box
REMBOX2, -4	Remote System Enclosure
REMBOX2-MP	Mounting Plate
REMBOX4-MP	Mounting Plate
PMI-REM	Remote PMI
PMI-INTL	PMI International
SSD, *SSD-C	System Status Display

04-14-03KK

HZM	Conventional Zone module
OD-LP, -BP, -GP	Door plate
ID-SP, -FP, *-MP	Door Plate
CAB1, CAB1R	Cabinet
BP-61, BTX-1, BTX-2, BTX-3	Battery Sets
HLIM	Loop Isolator Module
REL-EOL, EL-33	Resistor Kits
*BCM	Blank Control Module Plate

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as fire alarm control unit for use in high-rise applications when used in conjunction with listee's assorted Models for Voice Communication Accessories (CSFM Listing No. 6912-0067:237) and separately listed compatible initiating and indicating devices. Refer to listee's Installation Instructions Manual for details.

This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition.
Strobe devices can be controlled by the ZIC-4A for (synchronized or non-synchronized) operation.

04-14-03KK

Date Issued: **JUNE 9, 2003**   *Listing Expires **June 30, 2004***

*A*uthorized By: **DIANE K. AREND**, *Senior Deputy Program Manager*